



*Carroll Engineering Corporation*

February 7, 2019

William Ethridge, AICP  
Director of Planning & Zoning  
Westtown Township  
P.O. Box 79  
Westtown, PA 19395

Dear Will:

Subject: Malvern School

We have reviewed the revised plans for the proposed Malvern School at Wilmington Pike (SR 202) and East Pleasant Grove Road. From a public sewer standpoint, the current plan is acceptable. However, we note two non-sanitary sewer items that warrant revision. First, the Lateral Clean Out detail on sheet 2 should be revised, because the clean out projection boxed depicted on the detail conflicts with the standard Clean Out Protection Sleeve detail shown elsewhere on the drawing. The clean out projection sleeve is only required for the clean out in the parking lot. Second, we suggest that the Profile Existing Sewer East Pleasant Grove Road be changed to existing storm sewer.

Should you have any questions or require additional information, please feel free to contact this office.

Very truly yours,

CARROLL ENGINEERING CORPORATION

William N. Malin, P.E.

WNM:cam

*Today's Commitment to Tomorrow's Challenges*

Corporate Office:  
949 Easton Road  
Warrington, PA 18976  
215.343.5700

630 Freedom Business Center  
Third Floor  
King of Prussia, PA 19406  
610.489.5100

101 Lindenwood Drive  
Suite 225  
Malvern, PA 19355  
484.875.3075

105 Raider Boulevard  
Suite 206  
Hillsborough, NJ 08844  
908.874.7500