

PERMIT

For

INSTALLATION OF SEWAGE DISPOSAL SYSTEM

Pursuant to Application for Sewage Disposal System Number: Z212709
a permit is hereby issued to:

<u>Michael & Jacqueline Dibartolomeo</u>	<u>484-883-0052</u>	
Name of Applicant	Telephone Number	
<u>1078 Powderhorn DR, Glen Mills, PA 19342</u>	<u>5</u>	<u>600 gpd</u>
Address of Applicant	# of Bedrooms	Sewage Flow
<u>1078 POWDERHORN DR, WESTTOWN, PA 19342</u>	<u>Westtown Township</u>	<u>67-3-144.6</u>
Site Address	Municipality	Tax Parcel ID #

This permit issued under the provision of the "Pennsylvania Sewage Facilities Act", the Act of January 24, 1966 (P.L. 1535), as amended, is subject to the following conditions:

1. Except as otherwise provided by the Act or Regulations of the Pennsylvania Department of Environmental Protection no part of the installation shall be covered until inspected by the approving body and approval to use is granted in writing below as per Section 7(b) (3) of the Act.
2. This Permit may be revoked for the reasons set forth in Section 7 (b)(6) of the Act.
3. This Permit expires on 04/17/2023 unless construction of the building and system has commenced.
4. This Permit does not remove the necessity for obtaining Municipal building and/or zoning Permits. THIS PERMIT NOT TRANSFERABLE UNLESS APPROVED BY CHESTER COUNTY HEALTH DEPARTMENT.
5. Notify this Department at (610) 344-6526 or (610) 344-6688 upon starting construction of house and sewage system.
6. Obtain prior approval from this Department for any changes, revisions, deviations, etc.

Additional Conditions:

- A. As a condition of the Permit a timely private laboratory analysis of a representative sample of sandy fill material proposed to be used in the sewage system must be submitted. The analysis report must give the name of the proposed supplier and must indicate that the sandy fill material complies with Section 73.55(c), Chapter 73, Title 25 of the Pennsylvania Code.
- B. Restriction on sand placement due to improper soil conditions: 1) Sand shall not be placed on ground that has a high moisture content due to seasonal weather conditions; 2) Sand shall not be placed on ground that is partially or completely frozen.
- C. Restriction on drip tubing or At-Grade gravel placement due to improper soil conditions: 1) shall not be placed on ground that has a high moisture content due to seasonal weather conditions; 2) shall not be placed on ground that is partially or completely frozen.

Approval to Use

Date of Issuance of Permit 04/17/2020

Signature of Enforcement Officer

CHESTER COUNTY HEALTH DEPARTMENT

Approving Body

Date

Signature of SEO: Oxenford, Ryan

The basis for the issuance of this Permit is the information supplied in the Application for the Sewage Disposal System Permit. The Permit only indicates that the issuing authority is satisfied that the design and installation of the Sewage Disposal System is in accordance with the Rules, Regulations, and Standards of the Pennsylvania Sewage Facilities Act, the Act of January 24, 1966 (P.L. 1535), as amended. The issuance of a Permit shall not preclude the enforcement of other health laws, ordinances or regulations in the case of malfunctioning of the system.

SEE PERMIT CONDITIONS

1 - 6

TO BE POSTED AT THE BUILDING SITE

INSTALL SYSTEM
FOLLOWING
NATURAL GROUND
CONTOUR

MAINTAIN AT
MINIMUM
ISOLATION
DISTANCES

SEE ADDENDUM