

WESTTOWN TOWNSHIP
PUBLIC WORKS DEPARTMENT MONTHLY REPORT
NOVEMBER 2024

ROADS

- ◆ Removed 2 hazard trees from Pleasant Grove traffic circles.
- ◆ Repaired six stormwater inlets on Edgewood Chase and Powderhorn Dr.
- ◆ Cleared vegetation along the guide rail of Gilpin Drive.
- ◆ All vehicles outfitted with winter weather equipment.
- ◆ Removed a downed tree from across E. Pleasant Grove Road.
- ◆ After hours response to clear a downed tree from the 700 block of Oakbourne Road.
- ◆ Removed a dispatched deer from a fence per WEGO Police request.
- ◆ Removed small fallen limb on Robin Drive.

BUILDINGS, PARKS, AND OPEN SPACE

- ◆ Clean rain gutters of all buildings.
- ◆ Completed fall leaf clean-up at all buildings and parks.

OAKBOURNE PARK AND MANSION

1. Dug perc holes for design engineers to complete stormwater infiltration testing of the planned parking area reconstruction.
2. Serviced the mansion boiler and replaced the main gas valve.
3. Remove downed tree from a north woods walking trail.

PARKS AND OPEN SPACE

1. Cleared downed trees from the Pleasant Grove OS.
2. Inspected playground structures for safety hazards.

WASTEWATER

- ◆ Performed two separate force main tie-ins from the PGPS. These included bringing a repaired pump on-line and decommissioning the old force main.
- ◆ The PGPS force main project is 98% complete. PennDOT line painting and basic work area clean-up remain.
- ◆ Installed a repaired mixer motor at WCC.

EQUIPMENT MAINTENANCE AND REPAIR

- ◆ 67-17 – Repaired an oil pan leak of the engine.
- ◆ 67-11 – Rotated the tires.
- ◆ 67-23 – Repaired the headlight wiring harness.
- ◆ 67-20 – State Inspection and serviced engine.
- ◆ 67-29 – Crane controller faulty, waiting for manufacturer to repair.
- ◆ Repaired a faulty fuel injection check valve on the backhoe.

FUTURE PROJECTS

- ◆ Begin cleaning and televising segments of the WCC wastewater collection system.
- ◆ Continued monitoring of the Aqua water main installation project on Blenheim Road.
- ◆ Stump grinding in all parks.
- ◆ Return rental diesel sewage pump from PGPS.

MARK GROSS
DIRECTOR OF PUBLIC WORKS