

WESTTOWN TOWNSHIP
PUBLIC WORKS DEPARTMENT MONTHLY REPORT
DECEMBER 2024

ROADS

- ◆ Removed hazard tree from Cheyney Drive.
- ◆ Afterhours closure of Little Shiloh Road due to a tree on wires with fire.
- ◆ Welded a new safety screen on a stormwater inlet on Supplee Way.
- ◆ Removed a downed tree from the 700 block of Oakbourne Road.
- ◆ Performed salting of all roads on Christmas Eve due to an inch of snow.

BUILDINGS, PARKS, AND OPEN SPACE

- ◆ Installed perimeter safety fencing and no trespassing signage around two dilapidated houses on Crebilly Preserve.
- ◆ Installed two Crebilly Preserve signs.
- ◆ Checked and maintained heat and electricity at the Darlington Inn property; awaiting directions on additional work.
- ◆ Repaired a faulty garage door at the Public Works Complex.

OAKBOURNE PARK AND MANSION

1. Attended a planning meeting with the parking lot design engineers.
2. Ground three tree stumps in the park.
3. Cleaned the interior of first-floor windows in the mansion.
4. Drained the potable water line, winterized the restroom, removed tennis, pickleball, and basketball nets, and blocked off the large parking lot at the athletic core for the winter season.

PARKS AND OPEN SPACE

1. Ground three tree stumps in Pleasant Grove traffic circles.
2. Inspected playground structures for safety hazards.

WASTEWATER

- ◆ Removed temporary emergency diesel pump from PGPS.
- ◆ All standby generators serviced and inspected.
- ◆ Installed a new composite sampler at WCC.
- ◆ Began cleaning and televising of selected areas of the WCC sanitary sewer collection system.
- ◆ Met with design engineers for PGPS reconstruction planning.
- ◆ Located the Rustin Force Main for contractors at Westtown School.

- ◆ Sawmill court contractors made repairs to the sanitary tie-in manhole at WGPS.

EQUIPMENT MAINTENANCE AND REPAIR

- ◆ 67-23 – Repaired a corroded headlight wiring harness and replaced the washer pump.
- ◆ 67-23 – Rotated the tires.
- ◆ 67-10 – Replaced the transmission oil pan gasket due to a leak.
- ◆ 67-19 – Replaced a defective oil pan gasket on the engine.
- ◆ 67-29 – Crane controller faulty, waiting for manufacturer to repair.
- ◆ Repaired a faulty fuel injection check valve on the backhoe.

FUTURE PROJECTS

- ◆ Continue working with contractors on the sanitary sewer cleaning and televising project.
- ◆ Meet with design engineers to finalize design of the mansion core parking lot reconstruction project.
- ◆ Meet with design engineers on the PGPS replacement project.

MARK GROSS
DIRECTOR OF PUBLIC WORKS